

Attachment C - Ruawai Water Safety Plan risk table

| Stage                 | Event                         | No.  | Cause                                                                                                                      | Likelihood     | Consequence  | Max Risk | Indicators                                                                                                                                                                     | Preventive measures in place                                                                                                                                                                                                                                                                                                                                | Correction Actions                                                                                                                                                                                                                                                    | What to Check                                                                                                                                                                 | Risk Managed | Likelihood | Consequence   | Residual Risk | Acceptable | Confainty | Additional Measures                                                              | Resp      |
|-----------------------|-------------------------------|------|----------------------------------------------------------------------------------------------------------------------------|----------------|--------------|----------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------|------------|---------------|---------------|------------|-----------|----------------------------------------------------------------------------------|-----------|
| 1. Bore recharge zone | Microbiological contamination | 1.01 | Surface contamination from farming/ag activities in the adjacent area                                                      | Possible       | Catastrophic | High     | High raw water E. coli results, Turbidity in raw water, Prolonged heavy rain, extreme weather events, Illness in community                                                     | Implementation of RMA Planning Rules ie Regional Policy Statement, NES for Sources of Human Drinking-water. Land use consents. Subsequent treatment barriers effective against microbiological contamination. Over 100m setback from bores. Abstraction depths over 60M with confining layers<br>Testing has indicated that water in the aquifer to >1 year | Abstraction can be turned off and revert to treated water storage. Boil water notice can be issued. Incident response plan. Provision of tankered water                                                                                                               | Effectiveness of disinfection barriers, source water monitoring results<br>Land use changes. Weekly applications received from NRC for consents<br>Regional Council HAIL list | Yes          | Unlikely   | Minor         | Low           | Y          | Reliable  | Schedule raw water sampling.                                                     | WWM PDE   |
|                       | Microbiological contamination | 1.02 | Discharges from septic tank systems.                                                                                       | Possible       | Catastrophic | High     | High raw water E. coli results, Turbidity in raw water, Illness in community, Regional Council SoE reporting                                                                   | Implementation of RMA Planning Rules i.e. Regional Policy Statement, NES for Sources of Human Drinking-water. Treatment barriers effective against microbiological contamination. Building Act obligations for septic tanks. Abstraction depths over 60M with confining layers                                                                              | Abstraction can be turned off and revert to treated water storage. Boil water notice can be issued. District plan or Building Act abatement notices can be served. Provision of tankered water<br>The plant will shut down if the raw water turbidity exceeds 3.5 NTU | Compliance with consent conditions. Weekly applications received from NRC for consents                                                                                        | Yes          | Unlikely   | Minor         | Low           | Y          | Reliable  |                                                                                  | WWM PDE   |
|                       | Chemical Contamination        | 1.03 | Surface runoff containing chemical contaminants from agricultural/commercial activities.                                   | Possible       | Moderate     | Medium   | Taste and or odour. Information provided by Regional pollution hotline or public. Source water chemical screen indicates chemicals. Regional Council SoE reporting             | Implementation of Resource Management Planning Rules ie Regional Policy Statement, NES for Sources of Human Drinking-water. Subsequent treatment barriers oxidise some chemicals<br>HSNO control on using and handling chemicals. Regional Water Plan                                                                                                       | Abstraction can be turned off and revert to treated water storage. Incident response plan. Consumers advise water cannot be consumed.                                                                                                                                 | Chemical suite, trends in raw water composition<br>Regional Council HAIL list                                                                                                 | Yes          | Unlikely   | Minor         | Low           | Y          | Unsure    |                                                                                  | WWM PDE   |
|                       | Chemical Contamination        | 1.04 | Naturally occurring chemical contaminants e.g iron manganese                                                               | Almost Certain | Minor        | High     | Chemical analysis results identify chemical contaminants in excess of 50% of the DWSNZ MAVs                                                                                    | Subsequent treatment barriers oxidise some chemicals                                                                                                                                                                                                                                                                                                        | If there are any indications of chemical contamination of the source water in excess of DWSNZ MAVs or at levels that could be harmful, consumers must be advised not to consume the water                                                                             | Chemical suite results provide a biennial check, otherwise taste and odour complaints indicate contaminants are in surface water                                              | Partially    | Unlikely   | Insignificant | Low           | Y          | Confident |                                                                                  | WWM PDE   |
|                       | Chemical Contamination        | 1.05 | Chemical spill in recharge zone e.g traffic or boating accident in Wairoa river                                            | Possible       | Moderate     | Medium   | Notification or report to pollution hotline or emergency services call out<br>pH of raw water. Taste and odour                                                                 | Abstraction depths over 60M<br>Bores set back from road, low traffic area.                                                                                                                                                                                                                                                                                  | Abstraction can be turned off and revert to treated water storage. Incident response plan. Consumers advised water cannot be consumed. Provision of tankered water                                                                                                    | Timeliness of Reporting                                                                                                                                                       | Yes          | Unlikely   | Minor         | Low           | Y          | Reliable  | Develop notification procedures with NRC and Police to inform of chemical spills | WWM PDE   |
|                       | Chemical Contamination        | 1.06 | Use of herbicides or pesticides in recharge zone                                                                           | Possible       | Moderate     | Medium   | Source water chemical screen indicates chemicals. Regional Council SoE reporting. Weed control or pesticide controls programme operating                                       | Weed control programmes conducted to minimise run off. HSNO controls on use and certified operators used.<br>Abstraction depths over 60M with confining layers                                                                                                                                                                                              | Abstraction can be turned off and revert to treated water storage. Incident response plan. Consumers advised water cannot be consumed. Defer or cease operation                                                                                                       | Consents and approvals. Weekly applications received from NRC for consents                                                                                                    | Yes          | Unlikely   | Minor         | Low           | Y          | Reliable  |                                                                                  | WWM PDE   |
|                       | Chemical Contamination        | 1.07 | Saline intrusion                                                                                                           | Possible       | Minor        | Medium   | Source water chemical screen indicates salinity. Regional Council SoE reporting. Consumer complaints                                                                           | Abstraction depths over 60M with confining layers. Consent controls on adjoin land use activities e.g wharf area                                                                                                                                                                                                                                            | Abstraction can be turned off and revert to treated water storage. Incident response plan. Consumers advised water cannot be consumed. Provision of tankered water                                                                                                    | Consents and approvals                                                                                                                                                        | Yes          | Unlikely   | Insignificant | Low           | Y          | Reliable  |                                                                                  | WWM PDE   |
|                       | Loss of supply                | 1.08 | Drought reduces quantity of water that can be abstracted                                                                   | Possible       | Catastrophic | High     | Water levels and flow rates, weather conditions                                                                                                                                | Consent conditions for aquifer users. Visual checks. Regional Council monitoring programme provides for early detection.                                                                                                                                                                                                                                    | Initiate water demand and conservation management<br>Tanker supplies of treated water can be brought in during drought periods to overcome limitations of water source.                                                                                               | Catchment rainfall<br>Monitor leakage and high flow rates, send contractor to investigate.                                                                                    | Partially    | Unlikely   | Moderate      | Medium        | Y          | Reliable  |                                                                                  | WWM PDE   |
| 2. Bore and Well      | Microbiological contamination | 2.01 | Bore casing, bore head or well structure failure allowing for contaminated water getting into the bore from shallow depths | Possible       | Major        | High     | Positive E. Coli results from the bores or distribution system. Turbidity                                                                                                      | Asset management and maintenance<br>Bore head protection. Alarms at NTU >3.5                                                                                                                                                                                                                                                                                | Treated water storage. Incident response plan. Consumers advised water cannot be consumed. Provision of tankered water                                                                                                                                                | Raw water turbidity<br>Visual inspection of bore head and well structure<br>E. coli results                                                                                   | Yes          | Unlikely   | Minor         | Low           | Y          | Reliable  | Inspect bore casing 2 yearly<br>Schedule a CCTV inspection of the bore           | WWM PDE   |
|                       | Microbiological contamination | 2.03 | Flooding of the bore chamber                                                                                               | Possible       | Major        | High     | Positive E. Coli results from the bores or distribution system. Weather/flooding<br>Turbidity                                                                                  | Secure bore head protection installed including bore head above flood level<br>Alarms at NTU >3.5                                                                                                                                                                                                                                                           | Abstraction can be turned off and revert to treated water storage. Incident response plan. Consumers advised water cannot be consumed. Provision of tankered water                                                                                                    | Turbidity trends, particularly after heavy rain                                                                                                                               | Yes          | Unlikely   | Minor         | Low           | Y          | Reliable  |                                                                                  | WWM PDE   |
|                       | Loss of supply                | 2.04 | Mechanical or electrical failure of bore pumps                                                                             | Possible       | Major        | High     | Positive E. Coli results from the bores or distribution system<br>Flow logs from bores                                                                                         | Asset management and maintenance<br>Multiple Bores                                                                                                                                                                                                                                                                                                          | Abstraction can be turned off and revert to treated water storage. Incident response plan. Consumers advised water cannot be consumed. Provision of tankered water                                                                                                    | Maintenance logs                                                                                                                                                              | Yes          | Unlikely   | Minor         | Low           | Y          | Reliable  |                                                                                  | WWM PDE   |
|                       | Loss of supply                | 2.05 | Cannot abstract water due consent conditions                                                                               | Unlikely       | Major        | Medium   | Volume and flow to plants. Expiry date of existing resource consents.                                                                                                          | Implementation of Resource Management Planning Rules<br>SCADA shuts the plant down if volume exceeds the consent limit.                                                                                                                                                                                                                                     | Renew before expiry.                                                                                                                                                                                                                                                  | Any changing Regional Council policy                                                                                                                                          | Yes          | Unlikely   | Minor         | Low           | Y          | Confident |                                                                                  | WWM PDE   |
|                       | Loss of supply                | 2.06 | Intentional vandalism or accidental damage to the bore head or well                                                        | Unlikely       | Major        | Medium   | Volume and flow to plants. Visible damage, threats, reported suspicious activity                                                                                               | Exclusion zones around intakes and restricted access. Treated water storage. Legal deterrents. Intake structures designed to withstand some damage.<br>Subsequent treatment barriers                                                                                                                                                                        | Repairs, consumer advisory to conserve water                                                                                                                                                                                                                          | Raw water turbidity<br>Access to intakes, recreational water use                                                                                                              | Yes          | Unlikely   | Minor         | Low           | Y          | Confident |                                                                                  | WWM PDE   |
| 3. Raw Water Main     | Microbiological contamination | 3.01 | Ingress of surface/ground water into raw water line                                                                        | Possible       | Major        | High     | Positive E. Coli results from the bores or distribution system<br>Pumping and leakage<br>Turbidity                                                                             | Land use around raw water main provides some protection (mostly reserve land)<br>Maintenance & repairs<br>Treated water storage<br>Plant shut down >3.5 NTU                                                                                                                                                                                                 | Treated water storage. Incident response plan. Consumers advised water cannot be consumed. Provision of tankered water                                                                                                                                                | Online turbidity<br>Raw water sampling                                                                                                                                        | Yes          | Unlikely   | Minor         | Low           | Y          | Confident |                                                                                  | WWM PDE   |
|                       | Loss of supply                | 3.02 | Raw water main failure                                                                                                     | Possible       | Catastrophic | High     | Reduced/no flow to treatment plant<br>Low storage tank levels<br>Condition and type of materials of main<br>Condition assessment of raw main shows materials in poor condition | Maintenance & repairs<br>Treated water storage                                                                                                                                                                                                                                                                                                              | Incident response plan. Provision of tankered water                                                                                                                                                                                                                   | Raw water turbidity<br>Records of rising main failures and repairs                                                                                                            | Yes          | Unlikely   | Moderate      | Medium        | Y          | Confident |                                                                                  | WWM PDE   |
| tnment                | Particles not removed         | 4.01 | Insufficient oxidation (pre and post balance tank)                                                                         | Likely         | Moderate     | High     | Sodium hypochlorite use<br>Turbidity post filters                                                                                                                              | Oxidant dosing PLC controlled<br>Treated water storage<br>Subsequent treatment includes filtration barrier                                                                                                                                                                                                                                                  | Plant shut down if raw water >3.5NTU or pH outside 7-8 range                                                                                                                                                                                                          | Raw water turbidity<br>Balance tank level records                                                                                                                             | Yes          | Unlikely   | Minor         | Low           | Y          | Confident |                                                                                  | OEWS WO&M |

| Stage                     | Event                          | No.                                                      | Cause                                                                                    | Likelihood | Consequence  | Max Risk                                                                                                        | Indicators                                                                                                                                                                 | Preventive measures in place                                                                                                                                                                                                                                                       | Correction Actions                                                                                                                                               | What to Check                                                                                                                      | Risk Managed | Likelihood | Consequence | Residual Risk | Acceptable | Certainty                                                                                                     | Additional Measures                                                                                   | Resp         |
|---------------------------|--------------------------------|----------------------------------------------------------|------------------------------------------------------------------------------------------|------------|--------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------|--------------|------------|-------------|---------------|------------|---------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------|--------------|
| 4. Pre-trea               | Particles not removed          | 4.02                                                     | Insufficient (Filox) filtration of suspended solids, iron and manganese                  | Likely     | Moderate     | High                                                                                                            | Pressure differential<br>Turbidity post filters                                                                                                                            | 3 x Filox allow redundancy backwash sequence to maintain production<br>Back wash when filter pressure differential reaches set point or filter backwash at set cycle time or filter backwash at NTU setpoint<br>Balance tank allows constant feed to filters<br>Further filtration | Low balance tank level shuts of filtration                                                                                                                       | Turbidity<br>Balance tank level records                                                                                            | Yes          | Unlikely   | Minor       | Low           | Y          | Confident                                                                                                     |                                                                                                       | OEWS<br>WO&M |
| 5. Cartridge Filtration   | Particles/protozoa not removed | 5.01                                                     | Filter/cartridge malfunction including incorrect install/replacement                     | Likely     | Major        | High                                                                                                            | Turbidity<br>Filter pressure differential<br>Leaks around housing<br>Monitor High flow alarms                                                                              | Trained operators<br>Monitor Differential pressure and flow rates<br>Filter housing chlorinated when changing the cartridge<br>Water goes to waste for 3 minutes after start-up<br>Treated water storage<br>Maintenance & repairs                                                  | Replace the cartridge filter<br>Identify short comings in staff training and rectify<br>Shut down production<br>Investigate VSD or any other cause of high flows | Filtered water turbidity<br>Follow manufacturers instructions/speciation's<br>Treatment plant manuals                              | Yes          | Rare       | Moderate    | Low           | Y          | Confident                                                                                                     |                                                                                                       | OEWS<br>WO&M |
|                           | Particles/Protozoa not removed | 5.02                                                     | Filter media failure including breakthrough                                              | Likely     | Major        | High                                                                                                            | Filter pressure differential<br>High turbidity in water leaving the filter                                                                                                 | 2x Harmsco Filters allow some redundancy<br>Pre-treatment oxidation and Filox filters<br>Turbidimeters on each filter<br>Treated water storage                                                                                                                                     | Replace filter cartridge - held onsite<br>Shut down production >0.4NTU                                                                                           | Filtered water turbidity<br>Flow rates                                                                                             | Yes          | Unlikely   | Minor       | Low           | Y          | Confident                                                                                                     |                                                                                                       | OEWS<br>WO&M |
|                           | Particles/Protozoa not removed | 5.03                                                     | Filter media failure including clogging                                                  | Likely     | Major        | High                                                                                                            | Filter pressure differential<br>Flow meters                                                                                                                                | Pre-treatment oxidation and Filox filters<br>Turbidimeters on each filter<br>Treated water storage                                                                                                                                                                                 | Clean or Replace filter cartridge - held onsite<br>initiate water conservation measures                                                                          | Filtered water turbidity<br>Cleaning procedure                                                                                     | Yes          | Unlikely   | Minor       | Low           | Y          | Confident                                                                                                     |                                                                                                       | OEWS<br>WO&M |
|                           | Particles/Protozoa not removed | 5.04                                                     | Backwash pump failure                                                                    | Likely     | Major        | High                                                                                                            | Backwash cycle doesn't happen.<br>Increased post filter turbidity                                                                                                          | Regular maintenance of backwash pumps<br>Treated water storage                                                                                                                                                                                                                     | Shut down production                                                                                                                                             | Filtered water turbidity<br>Pumps monitored for noise and vibration                                                                | Yes          | Unlikely   | Minor       | Low           | Y          | Confident                                                                                                     |                                                                                                       | OEWS<br>WO&M |
|                           | Inadequate disinfection        | 6.01                                                     | Inadequate contact time                                                                  | Possible   | Major        | High                                                                                                            | Calculation of retention time determines contact time is inadequate<br>FAC levels<br>E. Coli or elevated coliforms trends in verification testing                          | Contact time provided by reservoir and mains<br>Groundwater source lower microbiological risk<br>Pre-treatment controls chlorine demand                                                                                                                                            | Chlorine dose point is set to 1.3mg/L (SCADA alarmed)                                                                                                            | Contact time, Microbiological quality, Flow rates, Post treatment FAC and pH                                                       | Yes          | Possible   | Minor       | Medium        | Y          | Reliable                                                                                                      |                                                                                                       | OEWS<br>WO&M |
| 6. Chlorination           | Inadequate disinfection        | 6.02                                                     | Sodium hypochlorite supply exhausted                                                     | Possible   | Catastrophic | High                                                                                                            | Illness in community.<br>FAC is less than 0.2 mg/L or E. coli detected in water in the distribution system.                                                                | Supply agreement with IXOM<br>Maintain 3 months chemical supply on-site<br>FAC is continuously monitored on-line with alarms to operators and date telemetered<br>Groundwater source lower microbiological risk<br>Pre-treatment controls chlorine demand                          | Low chlorine contingency                                                                                                                                         | Post treatment FAC<br>Drums onsite/turnover                                                                                        | Yes          | Rare       | Moderate    | Low           | Y          | Confident                                                                                                     |                                                                                                       | OEWS<br>WO&M |
|                           | Inadequate disinfection        | 6.03                                                     | Dosing system failure                                                                    | Likely     | Catastrophic | Extreme                                                                                                         | FAC is less than 0.2mg/L or E. coli detected in water in the distribution system.                                                                                          | Operator visits plant at least 2x week<br>FAC is continuously monitored with alarms to operators and shut down on low chlorine dose<br>Groundwater source lower microbiological risk<br>Pre-treatment controls chlorine demand<br>Supervised & trained operators                   | Repair and return to service<br>Calibration of analyser                                                                                                          | FAC alarms, on-line data and in distribution zone                                                                                  | Yes          | Unlikely   | Moderate    | Medium        | Y          | Confident                                                                                                     |                                                                                                       | OEWS<br>WO&M |
|                           | Inadequate disinfection        | 6.04                                                     | Automated chlorine dose rate incorrect                                                   | Likely     | Catastrophic | Extreme                                                                                                         | FAC is less than 0.2 mg/L or higher or E. coli detected in water leaving the WTP                                                                                           | Chlorine dose rate is flow paced<br>Operator visits the plant at least daily to check operation of chlorination system<br>FAC is continuously monitored on-line with alarms to operators and date telemetered                                                                      | If FAC sampling indicates incorrect FAC level, adjust dose rate as required                                                                                      | Post treatment FAC<br>FAC alarms, on-line data and in distribution zone                                                            | Yes          | Unlikely   | Minor       | Low           | Y          | Confident                                                                                                     | Update Operations and Maintenance manuals to reflect actual FAC target values as per actual practice. | OEWS<br>WO&M |
|                           | Inadequate disinfection        | 6.05                                                     | Chlorine demand exceeds chlorine dose due to dissolved Fe & Mg                           | Possible   | Catastrophic | High                                                                                                            | High turbidity in water.<br>Chlorine dose rate needs to be high to maintain an adequate residual<br>FAC is less than 0.2 mg/L or E. coli detected in water leaving the WTP | Source water has turbidity monitored and alarms<br>Operator visits the plant at least weekly to check operation of chlorination system<br>FAC is continuously monitored with alarms to operators                                                                                   | Increase chlorine dose level<br>Investigation filtration performance                                                                                             | Post treatment FAC<br>FAC alarms, on-line data and in distribution zone                                                            | Yes          | Unlikely   | Minor       | Low           | Y          | Confident                                                                                                     |                                                                                                       | OEWS<br>WO&M |
|                           | Inadequate disinfection        | 6.06                                                     | Lack of chlorine due to dosing line failure or leak.                                     | Possible   | Catastrophic | High                                                                                                            | FAC is less than 0.2mg/L or E. coli detected in water leaving the WTP<br>Strong chlorine smell at treatment plant                                                          | Operator visits the plant at least weekly to check operation of chlorination system<br>FAC is continuously monitored with alarms to operators and date telemetered                                                                                                                 | Repair chlorine dosing line                                                                                                                                      | Post treatment FAC<br>FAC alarms, on-line data and in distribution zone                                                            | Yes          | Unlikely   | Minor       | Low           | Y          | Confident                                                                                                     |                                                                                                       | OEWS<br>WO&M |
|                           | Over Chlorination              | 6.07                                                     | Dosing system failure.                                                                   | Possible   | Moderate     | Medium                                                                                                          | FAC level exceeds 1.3 mg/L setpoint leaving WTP<br>Odour and taste complaints                                                                                              | Operator visits plant at least 2x week<br>FAC is continuously monitored on-line with alarms to operators and date telemetered<br>Pre-treatment controls chlorine demand<br>Supervised & trained operators                                                                          | Advise consumers if high chlorine FAC is delivered to the distribution zone<br>Flush network if needed                                                           | Post treatment FAC<br>Operation of chlorine dosing pump<br>FAC alarms, on-line data and in distribution zone                       | Yes          | Unlikely   | Minor       | Low           | Y          | Confident                                                                                                     |                                                                                                       | OEWS<br>WO&M |
|                           | Over Chlorination              | 6.08                                                     | Chlorine dose rate incorrect                                                             | Possible   | Moderate     | Medium                                                                                                          | FAC level exceeds 1.3 mg/L setpoint leaving WTP<br>Odour and taste complaints                                                                                              | Chlorine dose rate is flow paced<br>Operator visits plant at least 2x week<br>FAC is continuously monitored on-line with alarms to operators<br>FAC>2.0mg/L<br>Pre-treatment controls chlorine demand<br>Supervised & trained operators                                            | Advise consumers if high chlorine FAC is delivered to the distribution zone<br>Flush network if needed                                                           | Post treatment FAC<br>Operation of chlorine dosing pump<br>FAC in reticulation system downstream of treatment plant                | Yes          | Unlikely   | Minor       | Low           | Y          | Confident                                                                                                     |                                                                                                       | OEWS<br>WO&M |
|                           | Micro contamination            | 7.01                                                     | Leakage through reservoir roof or other parts of structure or access by birds or vermin. | Likely     | Moderate     | High                                                                                                            | Visual evidence of leakage<br>E. coli in water leaving reservoirs                                                                                                          | Reservoir is covered and all entry hatches are locked against unauthorised access<br>Regular inspection of reservoirs is carried out. Asset condition assessment<br>Chlorine residual leaving reservoir monitored                                                                  | Repair any reservoir leaks or bird and vermin access points without delay.<br>Take out of service. Install replacement liners where feasible                     | Post reservoir FAC<br>Leakage from reservoir<br>Access points for birds and vermin<br>Evidence of birds or vermin inside reservoir | Yes          | Unlikely   | Minor       | Low           | Y          | Confident                                                                                                     | Review measures for protecting reservoirs from foreign matter                                         | OEWS<br>WO&M |
| Micro /chem contamination | 7.02                           | Vandalism or unauthorised entry to the storage reservoir | Possible                                                                                 | Moderate   | Medium       | E. coli in water leaving reservoir<br>Reports from the public<br>Evidence of damage or tampering with reservoir | Entry hatches locked against unauthorised access<br>Reservoir is located on land with restricted access.<br>Chlorine residual<br>Operator site visits                      | Inspect reservoir in response to reports of suspicious activity                                                                                                                                                                                                                    | Post reservoir FAC<br>Access hatches                                                                                                                             | Yes                                                                                                                                | Unlikely     | Minor      | Low         | Y             | Confident  | Improve documentation and audit process for contractors working on reservoirs or other treated water services | OEWS<br>WO&M                                                                                          |              |

| Stage           | Event                            | No.  | Cause                                                                                          | Likelihood     | Consequence  | Max Risk | Indicators                                                                                                                                                                                                                                                         | Preventive measures in place                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         | Correction Actions                                                                                                                                                                                                                                                     | What to Check                                                                                       | Risk Managed | Likelihood             | Consequence | Residual Risk | Acceptable | Confainty | Additional Measures                                                                                                                                    | Resp      |
|-----------------|----------------------------------|------|------------------------------------------------------------------------------------------------|----------------|--------------|----------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------|--------------|------------------------|-------------|---------------|------------|-----------|--------------------------------------------------------------------------------------------------------------------------------------------------------|-----------|
| 7. Storage      | Micro contamination              | 7.03 | Sediment accumulation within reservoir                                                         | Likely         | Moderate     | High     | Visible suspended matter in water in distribution system<br>Visible sludge in bottom of reservoir<br>Complaints from consumers                                                                                                                                     | Source has low sediment load and turbidity below 1 NTU<br>Regular inspection of reservoir is carried out and cleaning undertaken if required                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         | Isolate and clean reservoir as required                                                                                                                                                                                                                                | Post reservoir FAC<br>Check accumulation of sediment in reservoir every 5 years<br>Turbidity        | Yes          | Unlikely               | Minor       | Low           | Y          | Confident | Implement regular reservoir cleaning/scouring at a five year interval                                                                                  | OEWS WO&M |
|                 | Loss of supply                   | 7.04 | Failure of reservoirs                                                                          | Unlikely       | Catastrophic | High     | Complaints from consumers about loss of supply or pressure<br>Obvious signs of leakage or failure at reservoir site                                                                                                                                                | Assesst condition assessments. Reservoirs are constructed of concrete and steel.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     | Isolate damaged or failing reservoir and supply directly from treatment plant or use other reservoirs                                                                                                                                                                  | Visual assessment.<br>Structural integrity of reservoir                                             | Yes          | Rare                   | Moderate    | Low           | Y          | Confident |                                                                                                                                                        | OEWS WO&M |
|                 | Loss of supply                   | 7.05 | Insufficient storage for peak demand                                                           | Possible       | Catastrophic | High     | Loss of water or pressure in reticulation<br>Frequent low reservoir level                                                                                                                                                                                          | Planning controls on new development/connections<br>Treated water storage provides 228m3<br>Designed to achieve 2 days peak flow storage                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             | Introduce conservation and efficiency measures                                                                                                                                                                                                                         | Reservoir level                                                                                     | Partially    | Unlikely               | Moderate    | Medium        | Y          | Confident | Develop policy on supply of water incl restriction thresholds. Develop policy on climate change and associated modelling                               | OEWS WO&M |
| 8. Reticulation | Loss of water                    | 8.01 | Pump failure                                                                                   | Possible       | Major        | High     | Loss of water or pressure in reticulation<br>Frequent low reservoir level                                                                                                                                                                                          | Asset management, certified maintenance staff. Alarms                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                | Incident management plan. Demand restrictions imposed                                                                                                                                                                                                                  | Reservoir level                                                                                     | Partially    | Unlikely               | Moderate    | Medium        | Y          | Confident | Pumping- upgrade to duty and standby arrangement for pumping.<br>Hold spares allowing for repair/replace <24hrs                                        | OEWS WO&M |
|                 | Micro/Chem contamination         | 8.02 | Inadequate controls on maintenance and construction work                                       | Likely         | Major        | High     | Complaints from consumers about taste or odour. E. coli present in reticulation system                                                                                                                                                                             | Maintenance and replacement work is undertaken by trained qualified and experienced contractors. Specialist contractors used when required.<br>Council audit of contractors                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | Implement a boil water notice as outlined in the contingency plan if the quality of the water supplied cannot be assured                                                                                                                                               | Sanitation procedures and sanitation practices of contractors.                                      | Yes          | Unlikely               | Minor       | Low           | Y          | Confident | Review repairs for hygiene practice                                                                                                                    | OEWS WO&M |
|                 | Micro/Chem contamination         | 8.03 | Backflow from consumer connections.                                                            | Likely         | Moderate     | High     | Contaminants identified in the reticulation system. Taste or odour complaints from consumers.                                                                                                                                                                      | Council policy (Bylaw Part 16 - Water Supply). Maintain pressure in the supply (400kPa)                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              | Implement a boil water notice as outlined in the contingency plan if there is evidence of a backflow event                                                                                                                                                             | Land-use and building use changes                                                                   | Yes          | Unlikely               | Minor       | Low           | Y          | Confident | Improve backflow protection programme. Check pressures during high demand                                                                              | OEWS WO&M |
|                 | Loss of water                    | 8.04 | Unidentified leakage or illegal connections                                                    | Likely         | Minor        | Medium   | Consumption exceeds calculated expectation                                                                                                                                                                                                                         | Known breaks and leaks repaired as a priority. Illegal connections identified                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        | Repair leaks as priority. Disconnect or legitimise illegal connections                                                                                                                                                                                                 | Suspicions of illegal connections                                                                   | Yes          | Unlikely insignificant | Minor       | Low           | Y          | Reliable  |                                                                                                                                                        | OEWS WO&M |
|                 | Inadequate Supply                | 8.05 | Poor quality workmanship or inappropriate materials used for reticulation pipes and fittings   | Likely         | Moderate     | High     | Contaminants identified in the reticulation system. Taste and odour complaints from consumers                                                                                                                                                                      | Water supply bylaw. Materials used in reticulation to meet standard specifications. SoPs, and best practice reticulation approach taken to reticulation installation/repairs. Asset management and pipe replacement programme. GIS management of network and materials                                                                                                                                                                                                                                                                                                                                                                                                               | Redo work that has been poorly undertaken. Replace any materials that do not meet minimum specifications. Initiate incident management plan                                                                                                                            | Quality of work undertaken. Types of material used                                                  | Yes          | Unlikely               | Minor       | Low           | Y          | Reliable  | Reticulation - Improve audit and tracking process of SoPs. Ensure auditing of development manual requirements and contract requirements are undertaken | OEWS WO&M |
|                 | Sediment biofilm                 | 8.06 | Silt build up or biofilm within reticulation pipes                                             | Likely         | Minor        | Medium   | Reduced flows in reticulation. Complaints from consumer about quality of water. Low FAC readings in network. Reticulation NTU                                                                                                                                      | Flushing undertaken in response to complaints. Regular dead end mains flushing                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       | Undertake flushing as required                                                                                                                                                                                                                                         | Dirty water complaints                                                                              | yes          | Unlikely               | Minor       | Low           | Y          | Reliable  | Model network analysis to identify potential problem pressure areas<br>Install a flushing point at the dead end of reticulation.                       | OEWS WO&M |
| 9. Other        | Operator error mismanagement     | 9.01 | Inadequate training, professional development and up-skilling of operators                     | Likely         | Major        | High     | Staff not provided with adequate ongoing training.<br>Poor operation of plant.<br>Plant compliance failure.<br>Loss of supply.<br>Vacancies. Staff feedback.<br>WSP not properly understood and followed by staff.<br>Failure of staff to follow KDC QA procedures | Experienced staff employed. Staff attend appropriate professional conferences and other professional development opportunities. Operators have or are completing the National Cert or Dip in Drinking Water Treatment.<br>Appropriately experienced and qualified engineering personnel.<br>Regular staff training for new staff in particular.<br>Regular refresher and induction training for new staff. Contractor performance measures include completeness of required documentation and recording.<br>Up to date QA and O&M manuals.<br>Include key staff in the WSP process and provide training before and during implementation.<br>Comprehensive O&M Manual for the supply | Review documentation.<br>Provide in-house training where abilities are in deficit.<br>Amend the contract if service levels are inappropriate and/ or Council audit reveals weaknesses<br>Amend the WSP to include any new supply elements<br>Refer to Contingency Plan | Documentation.<br>Operator abilities, knowledge and training qualifications<br>Training attendances | Yes          | Unlikely               | Moderate    | Medium        | Y          | Reliable  |                                                                                                                                                        | OEWS WO&M |
|                 | Operator error mismanagement     | 9.02 | Inadequate supply planning and management                                                      | Likely         | Major        | High     | Lowering levels of service.<br>Consents not renewed.<br>Capital costs uncontrolled.<br>Failing infrastructure strategy.<br>3rd party audits e.g OAG. Reduction in funding                                                                                          | Relevant statutory obligations ie LGA, RMA, Council policies. Sub regional three waters strategy. Infrastructure planning team                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       | Apply contingencies for changes in legislation or other key planning considerations                                                                                                                                                                                    | New Legislation, regulations or Standards. Residential and industrial growth/connections            | Yes          | Possible               | Moderate    | Medium        | Y          | Confident |                                                                                                                                                        | OEWS WO&M |
|                 | Sampling Failure                 | 9.03 | Inadequate sampling programme or sample collection error.                                      | Likely         | Moderate     | High     | DWSNZ compliance failure due to days of week, days between samples, insufficient samples, information gaps, positive results or sampling error                                                                                                                     | Sampling programme prepared and checked against standards. IANZ accredited laboratory                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                | Review sampling programme                                                                                                                                                                                                                                              | Sampling programme against DWSNZ                                                                    | Yes          | Unlikely               | Minor       | Low           | Y          | Confident |                                                                                                                                                        | OEWS WO&M |
|                 | Unidentified Operational Failure | 9.04 | Insufficient monitoring and alarming of key operational data                                   | Almost Certain | Major        | Extreme  | Contamination identified in supply. Operational near miss identified. Inadequate information collected to provide confidence in supply operation                                                                                                                   | Continuous on-line alarmed monitoring for pH and turbidity at the treatment plant. Operators validate treatment plant equipment weekly and calibrate equipment as required                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           | Undertake manual grab sampling if required. Initiate incident management plan.                                                                                                                                                                                         | Trends and alarms of Cl2, pH and turbidity continuous monitoring                                    | Yes          | Unlikely               | Minor       | Low           | Y          | Confident | Data - review SCADA management                                                                                                                         | OEWS WO&M |
|                 | Inadequate Maintenance           | 9.05 | Supply equipment fails due to inadequate asset information and inadequate maintenance planning | Almost Certain | Moderate     | High     | Unexpected plant equipment failure.                                                                                                                                                                                                                                | Annual check and servicing of the chlorine dosing equipment with overhaul every two years<br>Subcontractor agreements<br>Active preventive maintenance programme in place                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            | Attend to failure as a priority Plan to renew or improve assets as required                                                                                                                                                                                            | Condition and forward planning for asset renewal asset register and maintenance programme           | Yes          | Unlikely               | Minor       | Low           | Y          | Reliable  |                                                                                                                                                        | OEWS WO&M |

| Stage | Event                         | No.  | Cause                                                                                                   | Likelihood     | Consequence  | Max Risk | Indicators                                                                                                                                                                                        | Preventive measures in place                                                                                                                                                                                              | Correction Actions                                                                                                                   | What to Check                                                                                           | Risk Managed | Likelihood | Consequence | Residual Risk | Acceptable | Confainty | Additional Measures                                                                                                                             | Resp      |
|-------|-------------------------------|------|---------------------------------------------------------------------------------------------------------|----------------|--------------|----------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|--------------|------------|-------------|---------------|------------|-----------|-------------------------------------------------------------------------------------------------------------------------------------------------|-----------|
|       | Failing to meet DWSNZ         | 9.06 | Treatment processes of the water supply are not sufficient to comply with the requirements of the DWSNZ | Almost Certain | Major        | Extreme  | Insufficient treatment processes at the treatment plant to comply with the DWSNZ                                                                                                                  | Continuous on-line alarmed monitoring for pH and turbidity at the treatment plant. Chlorination. E.coli and FAC monitoring                                                                                                | Implement boil water notice if safety of supply cannot be guaranteed                                                                 | DWSNZ compliance data                                                                                   | Yes          | Unlikely   | Moderate    | Medium        | Y          | Confident |                                                                                                                                                 | OEWS WO&M |
|       | Failure to Provide Safe Water | 9.07 | Inadequate data collection, reporting and control systems                                               | Likely         | Moderate     | High     | Information about how the supply is operating is not available. Manual collection and recording of data. IT failure                                                                               | Continuous on-line alarmed monitoring for pH, NTU, FAC at the treatment plant                                                                                                                                             | Undertake manual grab sampling if required                                                                                           | Trends and alarms of continuous monitoring                                                              | Yes          | Possible   | Moderate    | Medium        | Y          | Confident | Conduct a review of data storage capacity at treatment plants and remote RTU sites. Conduct a review of data collection, Storage and validation | OEWS WO&M |
|       | Microchem contamination       | 9.08 | Vandalism to plant equipment                                                                            | Possible       | Major        | High     | Obvious signs of damage to treatment or storage equipment Reduced/no flow to treatment plant or distribution system                                                                               | Controls and treatment plant are in robust concrete block buildings. Supply equipment is visited and checked regularly. Legal deterrents, ie prosecution                                                                  | Implement boil water notice if safety of supply cannot be guaranteed. Activate incident management plan. Provision of tankered water | Condition of treatment buildings and equipment                                                          | Yes          | Rare       | Moderate    | Low           | Y          | Confident | Establish security policy                                                                                                                       | OEWS WO&M |
|       | Loss of Supply                | 9.09 | Power fault or outage                                                                                   | Possible       | Catastrophic | High     | Power Company notifies planned outages<br>Plant production                                                                                                                                        | Maintenance inspection of internal wiring                                                                                                                                                                                 | Introduce conservation and efficiency measures<br>Provision of tankered water                                                        | Bring in emergency generator                                                                            | Partially    | Unlikely   | Moderate    | Medium        | Y          | Confident | Install on-site electricity generator interface                                                                                                 | OEWS WO&M |
|       | Total Plant Failure           | 9.10 | Catastrophic natural disaster or failure including earthquake and flooding                              | Rare           | Catastrophic | Medium   | Major natural disaster occurs. Intense sustained weather. Flooding. Total plant failure is evident. Warnings from Govt agencies incl Met Office, Niwa, Civil Defence, Regional Council or Police. | Prior warning from Govt agencies incl Met Office, Niwa, Civil Defence, Regional Council or Police. Robust secure plant structures and buildings. Business continuity plan in place and exercised. Emergency response plan | Implement all measures necessary to ensure plant continues to operate in a natural disaster                                          | Prior warnings issued by Govt agencies incl Met Office, Niwa, Civil Defence, Regional Council or Police | Partially    | Rare       | Major       | Medium        | Y          | Reliable  | Complete ERP                                                                                                                                    | OEWS WO&M |